


WSC 520 - WSC 540 - WSC 560

Declaration of Performance / Leistungserklärung / Ydeevnedeklaration

(DoP)

 0402
WindowMaster A/S, Skelstedet 13, DK-2950 Vedbæk 13 0402-CPD-SC0484-13
Electrical power supply equipment, intended to be used in smoke and heat controls systems. Elektrische Versorgungsgeräte, für den Einsatz in Rauch-und Wärmeabzugsanlagen. Elektrisk forsyningsudstyr, for anvendelse i forbindelse med brandventilation.
System 1
EN 12101-10 Operation class / Funktionsklasse / Funktionsklasse: A Environmental class / Umgebungsbedingungsklasse / Driftbetingelsesklasse: 1 IP rating / IP-Schutzart / Kapslingsklasse: IP 54 Interruption time / Unterbrechungszeit / Brydetid: < 2,0 sec Minimum Standby period / Min. Notstromversorgungszeit / Min. nødstrømforsyningstid: 72h Maximum capacity / Maximum Kapazität / Max kapacitet: WSC 520 2 x 18Ah WSC 540 4 x 18Ah WSC 560 6 x 18Ah Input / Versorgungsspannung / forsyningspænding: WSC 520: 1 x 230 VAC 50 HZ (±10%) WSC 540: 2 x 230 VAC 50Hz (±10%) WSC 560: 400 VAC (3 x 230VAC) 50Hz (±10%) Output current (Imax b)/ Ausgangsstrom (Imax b) / Udgangsstrøm (Imax b): WSC 520 20A, WSC 540 40A, WSC 560 60A Output voltage / Ausgangsspannung / Udgangsspænding: 24 VDC ± 15%
WindowMaster A/S: <i>Jan Norup</i> (Jan Norup, Head of group product management) Skelstedet 13, DK-2950 Vedbæk, 15 April 2013 Declaration no. 40 05 2013-CE