



Certificate of constancy of performance

0402 - CPR - SC0753-13

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Power supplies

for use in integrated control panels,
for use in smoke and heat control systems.

Product name: 3FC F01 and WSC 204 KP
Performances: Class A, Environmental class 1

placed on the market under the name or trademark of

WindowMaster International A/S

Skelstedet 13
DK-2950 Vedbæk
Denmark

and produced in the manufacturing plant

WindowMaster Industries GmbH, Hellerweg 180, DE-32052 Herford, Germany

This certificate attests that all provisions concerning the assessment and verification
of constancy of performance described in annex ZA of the standard

EN 12101-10:2005 and EN 12101-10:2005/AC:2007

under system 1 for the performance set out in this certificate are applied and that the factory
production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 2013-11-19 and will remain valid as long as neither the harmonised
standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant
are modified significantly, unless suspended or withdrawn by the notified product certification body.

2017-04-23

SP Technical Research Institute of Sweden
Certification, Notified Body No. 0402

Lennart Aronsson
Product Certification Manager

Martin Tillander
Certification officer